

Systemax 2000

Multivalve Electronic Controller

Customer Manual



Systemax 2000

Table of Contents


ITEM	PAGE
Introduction and General Description	3
Front Panel view and Description	3
Modes of Operation	4
Front Panel Displays	6
Programming	9
Quick Programming Guide	10
Option Settings Overview	11
System Programming Chart	12
Sample Unit programming Chart	15
Option Settings Programming - Detailed Information	17
Specifications	27
Input and Output Descriptions and Electrical Requirements	28
Controller Programming Worksheet	30
Enclosure Assembly Exploded View	32
Enclosure Assembly Parts List	33
Systemax Valve Wiring Diagram - Single Piston Valves	34
Systemax Valve Wiring Diagram - Dual Piston Valves	35
Troubleshooting	36

Systemax 2000

Controller Front Panel

Systemax 2000 Controller Description

The Systemax 2000 is a very flexible, state of the art, electronic valve control system. It is easy to install and use in a variety of commercial and industrial applications. The controller is remotely mounted in the vicinity of the softener / filter system. It connects to each valve in the system by means of an interlock cable assembly. Using time, flow meter inputs, or external signal inputs, the controller determines the service, Standby, or Regeneration status of each valve in the water treatment system. Auxiliary pumps, Chemical Feeders and Alarms can also be controlled by the Systemax. Step by step programming guides the user to custom tailor the system to their exact specifications.



Systemax 2000

Controller Modes of Operation

Start Mode

This mode is entered under any of the following three conditions:

1. AC power is restored with no battery backup installed or dead batteries.
2. The CPU resets due to power transients, malfunction, or the RESET button is pushed on the back of the display board.
3. A Front Panel Reset is initiated
(System Display and Unit 3 Display buttons are pushed simultaneously for 25 secs.)

This mode is required by the controller for it to properly initialize and that all of the units in the system are returned to their home or service positions prior to the controller proceeding to the next mode of operation. The sequence of events is:

Time (Seconds)	Display	Function
1 to 4	[S rXN.N]	Start mode indicated by a flashing 'S'. Software revision displayed.
5	[JP2XXXXX]	Position of Hardware jumper JP2 displayed. (Factory Set)
6 to 55	[DISPLAY]	All indicator LED's are tested during this time by sequencing through a fixed pattern. It is during this time that the user may fast abort the Start Mode by simultaneously depressing the Totalizer Reset and System Display buttons. The abort will immediately go to the last 5 seconds of the Start Mode and then to the No Auto Regeneration Mode.
56	[nn CYCLE]	The AC Line frequency detected is displayed.
57 to 60	[S rXN.N]	The flashing 'S' and Software revision is displayed one more time. Note: If the non-volatile memory is corrupt this entire sequence will repeat once.
61 and up		If Power-on Reset Mode is programmed for AUTOOrGEN, then the RESET mode is entered. If the mode is programmed for NO AUTO, then the No Auto Regeneration Mode is entered.

Reset Mode

This mode is entered after exiting the Start Mode with the Power On Reset Mode programmed for AUTOOrGEN. (Automatic Regeneration). This mode will synchronize the entire system to the controller by resetting all capacities to their maximums and all in-service / standby statuses to a known state. Because of this re-synchronization, this mode will also automatically be entered after changing the System Unit Size, the System Type, and/or the US/Metric setting in the programming mode. A lower case 'r' in the left most position in the Time of Day display and flashing LED's in the Manual Regeneration and System Program buttons will indicate that the controller is in the RESET Mode. After four minutes in this mode, the controller will proceed to regenerate each unit in the system one after the other starting with Unit #1 and on up. If the user wishes to immediately begin this series regeneration sequence, then a System Manual Regeneration should be initiated as follows: First press the Manual Regeneration button and then press the System Program button.

No Auto Regeneration Mode

This mode skips the automatic series regeneration of the Reset Mode. It restores the system to the last known state of the controller as saved in the non-volatile memory. (The controller status is saved upon exiting of programming or every hour, on the hour.) All system capacities, service, and standby states are restored. However, if a unit was in regeneration when the Start Mode was entered, then that unit will be placed back in regeneration at the start of the regeneration sequence. The time of day display will not be flashing to indicate that power was lost or the unit reset. The controller should be run through the RESET Mode at least once on initial start-up before being programmed to this mode.

Systemax 2000

Controller Modes of Operation - Cont'd.

Normal Operation Mode

In this mode the Time Of Day/Day Of Week Display will be typically viewed on the VFD. Other displays, Flow Rate, Peak Flow Rate, Volume Remaining, Reserve Capacity, Totalizer, Time Since Last Regeneration, or Prior Service Volume Used may also be viewed in this mode. Programming can be entered, the current time of day/day of the week changed, or manual regeneration initiated at any time.

The controller will immediately return to this mode after all other modes of operation have ended.

Controller Operation During Regeneration

The controller will continue to operate in a normal manner while a unit is in regeneration. Status displays for each unit in the system will be available at all times. The unit in regeneration however, will not be able to view its Time Of Day Display, instead it will display a Regeneration Display. This display will show the step # and the time left in that regeneration step in minutes and seconds [**2- -100.25**]. The step # will also flash when the unit is between regeneration steps. After regeneration is complete the Time Of Day Display will return.

Controller Operation During Power Outage

During a power outage, the controller will continue to operate in a normal manner from a battery backup. The controller will keep all active data displays and memories up to date but will be unable to display them until line power is restored. The controller will delay the initiation of a regeneration cycle during a power outage and will not energize any outputs until line power is restored. Only the Low Battery LED will function. The controller will also not be capable of being programmed. Upon exiting of programming or every hour, on the hour, the controller will store into permanent memory the following displays, to be used upon power reapplication:

- | | |
|------------------------------|---------------------|
| 1. Time Of Day / Day Of Week | 3. Volume Remaining |
| 2. System Status | 4. Totalizer |

Program Mode


Whenever a Program Select Button is pushed, the controller will enter the Program Mode provided that a unit is not in regeneration. In this mode the system or an individual unit program is set up by the operator. If the System Program Select Button is being used, pushing the Up/Down Arrow Buttons to adjust the setting will cause the identical value to be programmed into all units of the system. The programmer can then custom tailor individual valve programming by pushing a specific units Program Select Button and setting options as necessary. While in this mode the controller will continue to operate the system in a normal manner.

The controller will guide the programmer through all the necessary settings by displaying only valid option combinations.

Systemax 2000

Front Panel Displays

Up to eight displays may be viewed on the VFD by pushing the required unit's Display Select button



Time Of Day / Day Of Week Displays

The current time of day is displayed as four digits, with hours and minutes separated by a flashing decimal point. An indicator arrow will show the current day of the week. Time of day may be 12 or 24 hour. If this display is flashing, then the unit has gone through the Reset Mode. Press any key to stop the flashing.

Volume Remaining / Reserve

The Volume Remaining Display is used to view the current volume of treated water available, including reserve. The volume unit used will be gallons or litres, depending on the US/metric setting. The maximum value of this display is determined by the current Capacity option setting. Whenever the Volume Remaining Display reaches the reserve capacity or a Sensor Input has received a signal, the reserve indicator arrow will begin to flash on the VFD.

A second display, *Reserve*, is used to view the current calculated reserve capacity for that unit or system. An **(r)** located in the left side display digit will indicate this second display. Either display will not be able to be viewed if a flow meter is not used. There will not be a reserve display with any immediate regeneration types.

Flow Rate / Peak

The Flow Rate Display is used to view the rate of treated water usage. The current flow rate will be displayed up to 999.9 volume units per minute. The rate unit used will be gallons or litres per minute, depending on the US/metric setting. The current flow rate is determined by the elapsed time taken to accumulate a specified number of pulses from the flow meter.

A second display, Peak Flow Rate, is used to view the maximum flow rate recorded since the unit was powered up, or midnight on Sunday. The letter **(P)** located in the left side display digit will indicate this second display. Either display will not be able to be viewed if a flow meter is not used.

Totalizer

The Totalizer Display records the total amount of water treated by the system. The display will reset to zero when 100 million is reached. The volume unit used will be gallons or litres, depending on the US/metric setting. This display will not be able to be viewed if a flow meter is not used.

Time Since Last Regeneration


The Time Since Last Regeneration Display records the number of days and hours since the last regeneration of selected unit/system.

Prior Service Volume Used

The Prior Service Volume Used Display records the volume of treated water used between the most recent regeneration and the second most recent regeneration. The volume unit used will be gallons or litres, depending on the US/metric setting. This display will not be able to be viewed if a flow meter is not used.

Systemax 2000

Front Panel Displays - Cont'd



Controller Status Indicators


Active at all times for all units in the system

(A) Low Battery Indicator

A red LED to the left of the VFD is used to indicate that the battery backup needs to be replaced.

(B) P.M. Indicator

A green LED to the right of the VFD is used as a P.M. indicator. This will only be active in U.S. mode.



System Status Indicators

Active at all times for all selected units in the system

(C) Service Indicators -

A green LED is used to indicate that a unit is in service.

A *flashing* green LED is used to indicate that a regeneration is pending or a unit is leaving service for regeneration.

(D) Standby Indicators -

A green LED is used to indicate that a unit is in standby.

A *flashing* green LED is used to indicate that a regeneration is leaving standby.


(E) Regeneration Indicators -

A green LED is used to indicate that a unit is in regeneration.

A *flashing* green LED is used to indicate that a regeneration is leaving regeneration

Systemax 2000

Front Panel Displays - Cont'd



Unit Status Indicators

Activated by pushing the desired unit's Display Selector Button.

Regeneration Cycle Status Indicators

A green LED is used to indicate which step of regeneration cycle a specific unit is in.

(B) Flow Meter Input Indicator

A green LED will flash at the rate pulses are being received by the controller from a flow meter. This indicator will only be active when a metered Regeneration Type is set.

(C) Sensor Input Indicator

A green LED is used to indicate that a Sensor Input Signal is being received from the unit number selected. This LED will flash (per set Minimum Signal Time) until the received signal is considered valid, then stay on until the signal is removed. This indicator will only be active when a Sensor Regeneration Type option is set.

(D) Regeneration Lockout Indicator

A yellow LED is used to indicate that a Regeneration Lockout Input Signal is being received from the unit number selected. This LED will flash (per set Minimum Signal Time) until the received signal is considered valid, then stay on until the signal is removed. This LED will be active only with the Regeneration Lockout Option selected.

(E) Valve Drive Output Indicator

A green LED is used to indicate that a Valve Drive Output Signal is being sent to the unit number selected.

(F) Timed Auxiliary Output #1 Indicator

A green LED is used to indicate that this unit's output is active.

(G) Timed Auxiliary Output #2 Indicator


A green LED is used to indicate that this unit's output is active.

Brightness Correction Display:

Everyday at 3:00 A.M. the control will turn on the full VFD. As a result, all digits, dots, and arrows will be brightly displayed for 10 minutes. This feature is used to keep the display uniformly bright throughout its operational life. The controller will continue to function in the background normally during the duration of this display. Normal display operation will return automatically after this period of time is over or if any button is pushed.

Systemax 2000

Controller Programming



Option Setting Display

Used as an aide to the programmer in selecting the desired display to be programmed. A LED indicator will turn on next to the current display being viewed.

Program Select Buttons

Used to program system or individual unit operation using up to 33 different option setting displays indicated above by LEDs.

Program Select Buttons

In normal operation these buttons are used by the user to enter the Program Mode, instruct the controller to manually initiate a regeneration of a unit, or reset a specific Totalizer Display. In the Program Mode various option settings are viewed and or set by pushing the desired units (or System) Program Select Button once per display until the desired one is viewed. Pushing the active Program Select Button after viewing the last option setting will exit the user from this mode.

If the Program Lockout feature is active, the programmer will have to push and hold the desired Program Select Button for a preselected amount of time before access is granted to System/Unit programming.

Set Up and Set Down Buttons

These two buttons are used to set all adjustable display values as desired. When the Up Arrow Button is pushed the display will increase in value. When the Down Arrow Button is pushed the display will decrease in value. When either button is pushed and held, the display value will change slowly at first and then slowly increase (or decrease) in speed until a maximum speed is reached.

Manual Regeneration Button

This button is used to manually initiate an additional regeneration of the system or unit. When a Unit # Program Select Button is selected after pushing this button, a regeneration cycle of that unit is immediately initiated.

When the System Program Select Button is pushed after selecting this button, the controller will automatically determine which unit will initiate a regeneration cycle immediately. This decision will be based on current system status as well as the current option settings.

This button will be ignored with one unit already in Regeneration and the controller is configured as either a 2 or 3 Unit System #5 thru #13. With System #6 configurations, and System selected, the controller will automatically regenerate the total system starting with Unit #1.

When pushed, this button will light up until the regeneration cycle is complete.

Systemax 2000

Controller Programming - Cont'd.

Stepping A Unit Through A Regeneration Cycle

Pushing the Program Select Button of a unit in regeneration will instruct the controller to advance the unit immediately to the next regeneration cycle step. By repeating this procedure each unit in the system can be stepped through its full regeneration cycle.

The user may advance or reverse the time remaining within a regeneration cycle step by pushing either the Set Up or Set Down Button until the desired time remaining appears. Regeneration cycle programming will not be changed and normal step timing is resumed.

Totalizer Reset Button

This button is used to reset the system's or individual unit's Totalizer Display. This display is reset by first selecting the Totalizer Reset Button then pushing and holding for 25 seconds the desired units Program Select Button. The desired units Program Select Button LED will flash rapidly during this 25 seconds then turn off once the display is reset. On a single flow meter system, the System Program Button must be held.

Quick Programming Guide

As an aid to the programmer, the controller will guide the programmer to which option settings need to be set, or can be set, for the numerous types of systems available.

- #1** Set all option displays contained under System Program Select Button.
- #2** Exit System Programming. All system settings will be automatically duplicated and stored in each individual units program. Regeneration Cycle Steps #1 Thru #6 Option Settings, for example.
- #3** Controller programming is complete at this point if all units are to have the same settings.
- #4** If there needs to be differences in settings, custom tailor individual unit programming by adjusting any settings contained under a Units Program Select Button.

All controller programming is stored in permanent memory. In event of a power outage and battery backup failure, all programming will remain intact upon controller power up. There will be no need to reprogram the controller other than reset the present time of day.

Systemax 2000

Option Settings

The following option settings are used to program the controller. They can be viewed by pushing the Program Select Button for that unit or System, once per display setting until the desired one has been reached.

US/metric

This option is used to select 12 or 24 hour timekeeping, and gallon or litre volume units.

Time Of Day / Day Of Week

This option setting is used to set the current time of day and day of week.

System Unit Size

This option setting is used to select the number of units in the system.

Valve Type

This option setting is used to select how a unit will operate in the system based on a specific type of valve.

System Type

This option setting is used to select the way the controller is to operate in conjunction with other units, if any.

Regeneration Type

This option setting is used to select the way the time to regenerate decision is to be made by the controller.

Regeneration Time

This option setting is used to set the regeneration start time for any Delayed Regeneration Type.

Flow Meter Size

This option setting is used to set the proper calibration of a Flow Meter Input.

Capacity

This option setting is used in calculations made by the controller in determining when to initiate a regeneration.

Regeneration Override

This option setting is used to force a regeneration to occur at a certain minimum frequency.

Regeneration Cycle Step Programming

This series of six option settings is used in creating a regeneration cycle program for each unit in the system.

Timed Auxiliary Output #1

This option setting is used to set the turn on/off time for a unit's Timed Auxiliary Output #1.

Timed Auxiliary Output #2

This option setting is used to set the turn on/off time for a unit's Timed Auxiliary Output #2.

Regeneration Lockout (RL)

When this option is selected, the controller will not let a unit go into regeneration until the signal being received at that unit's Regeneration Lockout Input is removed.

Program Lockout

When this option is selected, the controller will not let the user go into the Program Mode until the desired Program Select Button is pushed and held for a preselected amount of time before access is granted.

Power On/Reset Mode Select

This option determines how the controller operates after AC power is restored without battery backup.

Systemax 2000

System Programming Chart

System Programming Is Entered (System program Select button is pushed once per display until exit)		
Optional	[- - - - - XXX]	US / Metric (Set desired display code)
System Program	[- - X X.X X - -] [- - - - - ▾]	Time of Day / Day of Week (Display to set current time of day) (Display to set current day of week)
System Program	[- - - - - X]	System Unit Size (1 - 3) (Display to set the number of units installed in the system)
Optional	[X ONLINE]	(Display to set the number of units installed in the system)
System Program	[- - - - - X]	Valve Type (Display to set the display code for the type of valve(s) used)
System Program	[- - - - - X]	System Type (Viewed only with multi-unit systems) (Set desired display code)
System Program	[- - - - - X]	Regeneration Type (Set desired display type)
Optional	[XX - - - - 10] (XX Flashes)	(Viewed only with #10 selected) (Set type of regeneration)
Optional	[XXX.X - - - X] (XXX Flashes)	(Viewed only with #6 - #9, #12, #13) selected) (Set minimum signal time)
Optional	[1 - S - XX.XX]	Regeneration Time (Set desired time of day for start of Regeneration Window #1) (Viewed only with delayed types of regeneration).
Optional	[1 - E - XX.XX]	(Set time of day for end of Regeneration Window #1)
Optional	[2 - S - XX.XX]	(Set time of day for start of Regeneration Window #2, if desired)
Optional	[2 - E - XX.XX]	(Set time of day for end of Regeneration Window #2)

Systemax 2000

System Programming Chart - Cont'd.

Optional	[-- X X.X X --]	Flow meter Size (Set desired display code) (Viewed with Regeneration Types #2 - #5. #8, #9, #11 and #13)
Optional	[X,XXX --- 6] (XXX,X Flashes)	(Viewed only with #6 selected - Set pulses per litre) (Cannot be set as 0000)
Optional	[XX,XXX,XXX]	Capacity (Viewed with Regeneration types #2 - #5 and #11) (Set Litres)
System Program	[CAL -- XXX]	Regeneration override (Display to activate Calender Day Regeneration Override feature)
Optional	[-----XXX]	(Display to set active/inactive Calender Days -(Set yes or no)
Optional	[-----XXX]	(Display to activate Standard Override - Set number of days)
Regeneration Cycles (1 - 6)		
System Program	[1 --- XXX.X]	Regeneration Cycle Step #1 (Display to set regeneration cycle step timing in minutes)
System Program	[2 --- XXX.X]	Regeneration Cycle Step #2 (Display to set regeneration cycle step timing in minutes)
Optional	[3 --- XXX.X]	Regeneration Cycle Step #3 (Display to set regeneration cycle step timing in minutes)
Optional	[4 --- XXX.X]	Regeneration Cycle Step #4 (Display to set regeneration cycle step timing in minutes)
Optional	[5 --- XXX.X]	Regeneration Cycle Step #5 (Display to set regeneration cycle step timing in minutes)
Optional	[6 --- XXX.X]	Regeneration Cycle Step #6 (Display to set regeneration cycle step timing in minutes)
Optional	[CPO -- XXX]	Timed Auxiliary Output #1 (Display to activate Chemical Pump Output feature) (Viewed with Regeneration Types #2 - #5. #8, #9, #11 and #13)
Optional	[UOLXX,XXX]	(CPO OP#1 Display to set Output Activation Volume - Litres)
Optional	[runX,XXX.X]	(CPO OP#1 Display to set Output Run Time - Minutes)



Systemax 2000

System Programming Chart - Cont'd.

		Timed Auxiliary Output #1 - cont'd.
Optional	[On - XX,XXX]	(CPO OP#2 Display to set Output Activation Volume) (Set in litres)
Optional	[OFFXX,XXX]	(CPO OP#2 Display to set Output Run Time - Set in minutes)
Optional	[S - - X,XXX.X]	(Display to set Standard Output Mode Start Time - Set in minutes)
Optional	[E - - X,XXX.X]	(Display to set Standard Output Mode Start Time - Set in minutes) (Start / End Times referenced to start of regeneration cycle #1)
		Timed Auxiliary Output #2
Optional	[CPO - - XXX]	(Display to activate Chemical pump Output feature) (Viewed with Regeneration types #2 - #5, #8, #9, #11 and #13)
Optional	[UOLXX,XXX]	(CPO OP#1 Display to set Output Activation Volume) (Set in litres)
Optional	[runX,XXX.X]	(CPO OP#1 Display to set Output Run Time) (Set in minutes)
Optional	[On - XX,XXX]	(CPO OP#2 Display to set Output Activation Volume) (Set in litres)
Optional	[OFFXX,XXX]	(CPO OP#2 Display to set Output Run Time) (Set in minutes)
Optional	[S - - X,XXX.X]	(Display to set Standard Output Mode Start Time) (Set in minutes)
Optional	[E - - X,XXX.X]	(Display to set Standard Output Mode Start Time) (Set in minutes) (Start / End Times referenced to start of regen cycle #1)
<input type="radio"/> System Program	[- - - - XXX]	Regeneration Lockout (Display to activate regeneration lockout input)
Optional	[XXX.X - XXX] (XXX flashes)	(Viewed only with On1 - On4 set - Set minimum signal time)
<input type="radio"/> System Program	[PL - - -XXX]	Programming lockout (Display to activate lockout feature - Set lockout time in seconds)
<input type="radio"/> System Program	[AUTOrGEN] [NO AUTO]	Power On / Reset Mode (Display to set controller reset feature) (Set to either display as required)
		System programming Is Exited (Normal Operation mode is re-entered)

















Systemax 2000

Sample Unit Programming Chart

Unit programming Is Entered (Unit #2 Program Select Button is pushed once per display until exit)		
	[- - - - - X]	Regeneration Type (Set desired display type)
Optional	[XX - - - - 10] (XX Flashes)	(Viewed only with #10 selected) (Set type of regeneration)
Optional	[XXX.X - - - X] (XXX Flashes)	(Viewed only with #6 - #9, #12, #13) selected) (Set minimum signal time)
Optional	[1 - S - XX.XX]	Regeneration Time (Set desired time of day for start of Regeneration Window #1) (Viewed only with delayed types of regeneration).
Optional	[1 - E - XX.XX]	(Set time of day for end of Regeneration Window #1)
Optional	[2 - S - XX.XX]	(Set time of day for start of Regeneration Window #2, if desired)
Optional	[2 - E - XX.XX]	(Set time of day for end of Regeneration Window #2)
Optional	[- - X X.X X - -]	Flow meter Size (Set desired display code) (Viewed with Regeneration Types #2 - #5, #8, #9, #11 and #13)
Optional	[X,XXX - - - 6] (XXX,X Flashes)	(Viewed only with #6 selected - Set pulses per litre) (Cannot be set as 0000)
Optional	[XX,XXX,XXX]	Capacity (Viewed with Regeneration types #2 - #5 and #11) (Set Litres)
	[CAL - - XXX]	Regeneration override (Display to activate Calender Day regen Override feature)
Optional	[- - - - -XXX] ▼	(Display to set active/inactive Calender Days -(Set yes or no)
Optional	[- - - - -XXX]	(Display to activate Standard Override - Set number of days)

Systemax 2000

System Programming Chart

	
 [1 --- XXX.X]	Regeneration Cycles (1 - 6) Regeneration Cycle Step #1 (Display to set regeneration cycle step timing in minutes)
 [2 --- XXX.X]	Regeneration Cycle Step #2 (Display to set regeneration cycle step timing in minutes)
 [3 --- XXX.X]	Regeneration Cycle Step #3 (Display to set regeneration cycle step timing in minutes)
 [4 --- XXX.X]	Regeneration Cycle Step #4 (Display to set regeneration cycle step timing in minutes)
 [5 --- XXX.X]	Regeneration Cycle Step #5 (Display to set regeneration cycle step timing in minutes)
 [6 --- XXX.X]	Regeneration Cycle Step #6 (Display to set regeneration cycle step timing in minutes)
<hr/>	
Timed Auxiliary Output #1 Skipped due to settings in System Programme	
<hr/>	
 [CPO -- XXX]	Timed Auxiliary Output #2 (Display to activate Chemical pump Output feature) (Viewed with Regeneration types #2 - #5, #8, #9, #11 and #13)
 [UOLXX,XXX]	(CPO OP#1 Display to set Output Activation Volume) (Set in litres)
 [runX,XXX.X]	(CPO OP#1 Display to set Output Run Time) (Set in minutes)
 [On - XX,XXX]	(CPO OP#2 Display to set Output Activation Volume) (Set in litres)
 [OFFXX,XXX]	(CPO OP#2 Display to set Output Run Time) (Set in minutes)
 [S -- X,XXX.X]	(Display to set Standard Output Mode Start Time) (Set in minutes)
 [E -- X,XXX.X]	(Display to set Standard Output Mode Start Time) (Set in minutes) (Start / End Times referenced to start of regen cycle #1)
<hr/>	
 [- - - - - XXX]	Regeneration Lockout (Display to activate regeneration lockout input)
 [XXX.X - XXX] (XXX flashes)	(Viewed only with On1 - On4 set - Set minimum signal time)
<hr/>	
System programming Is Exited (Normal Operation mode is re-entered)	

Systemax 2000

Option Setting Programming

The following option settings are available to be programmed by pushing either the Up or Down Set Button:

US/Metric Option Setting Display

This option setting display has a one digit display with two settings

- 1 - US Mode
- 2 - Metric Mode

With #1 set, the controller will use US units (gallons, g.p.m.) and a 12 hour timekeeping format.
With #2 set, the controller will use metric units (litres, l.p.m.) and a 24 hour timekeeping format.

Time of Day/Day of Week

This option setting consists of two displays. Display #1 sets the current time of day. Display #2 sets the current day of the week. Both displays may also be reset in normal operation by the Up/Down Set Buttons.

System Unit Size

This option setting informs the controller on the number of units to be operating in the system. This option setting has three settings, 1-3, which correspond to the number of units connected to the controller.

Valve Type

When this option is selected, the controller will configure itself to operate with one of 6 different types of valves. The options available and their display codes are:

- | | |
|--|--|
| 1 - Standard Downflow Brining Valve(s)
"Butterfly Cam" Type Stagers | 4 - Diaphragm Valve Stager
("Notched Cam" Type) |
| 2 - Valve type #1 with Regen. Flow Monitor | 5 - Standard Upflow Brining Valve(s) |
| 3 - 2900/3900 Downflow Brining Valve(s) | 6 - 2900/3900 Upflow Brining Valve(s) |

When #1 or #5 is selected:

Systems with individual flow meters - The Volume Remaining Display will reset at the start of Regeneration and any Flow Meter input signals received during Regeneration are ignored until the unit returns to Service.

Systems with a single system flow meter - The volume Remaining Display will reset at the start of Regeneration and any Flow Meter Input signals received from Regeneration through Service will be counted. The Lower Drive Input will be ignored with both system types. When Valve Type #5 is set the default times for the Regeneration Cycle are changed and the regeneration cycle step indicator operation is modified.

When #2 is selected:

The Volume Remaining Display will reset at the start of Regeneration and any Flow Meter Input signals received from Regeneration through Service will be counted. The Lower Drive Input will be ignored.

When #3 or #6 is selected:

Systems with individual flow meters - The Volume Remaining Display will reset at the start of Regeneration and any Flow Meter Input signals received during Regeneration are ignored until the unit returns to Service.

Systems with a single system flow meter - The Volume Remaining Display will reset at the start of Regeneration and any Flow Meter Input signals received from Regeneration through Service will be counted.

The Lower Drive Input will be monitored at all times. A signal present at this input will indicate that the Lower Drive Valve is in a regeneration or standby position. The controller will not let another unit to go into regeneration or standby until this signal is removed. The controller will indicate that it is waiting for the Lower Drive Valve Signal to be removed by flashing either the Regeneration or Standby Status LED for that specific unit. A signal absent at this input will indicate that the Lower Drive Valve is in a service position. The controller will indicate that it is waiting for this signal to be sent by flashing the Service Status LED for that specific unit.

Systemax 2000

Option Setting Programming - Cont'd

If the Lower Drive Input Signal is not removed within 60 seconds (returning a unit to service) or received within 60 seconds (sending a unit to regeneration or standby) a Lower Drive Error Message (Ld Error) will be scrolled across the VFD. Also, the Program Selector Button LED for the unit with the error will flash rapidly. Any calls for regeneration or of bringing units back into service will be delayed until this error is cleared. This is done automatically by removing the error condition. When Valve Type #6 is set, the default times for the regeneration cycle are changed, and the regeneration cycle step indicator operation is also modified.

When #4 is selected:

The Volume Remaining Display will reset at the start of Regeneration and any Flow Meter Input signals received during Regeneration are ignored until the unit returns to Service. The Lower Drive Input will be ignored. The controller will operate the stager in a normal manner with special cam (Home and Step Input) logic.

System Type Option Setting Display

This option setting configures the controller for use in multi-unit systems. The display has a range of 5-13.

4 - System #4 Single Unit/9000 /Timeclock, Meter or Sensor Regeneration.
(Single unit default setting, not viewed)

The following types of systems may be selected:

- 5 - System #5 Individual Timelock, Meter, or Sensor Interlocked Regeneration - 2 or 3 units
- 6 - System #6 Single Timeclock Meter, or Sensor Series Regeneration - 2 or 3 units
- 7 - System #7 Single Timeclock, Meter, or Sensor Alternator Regeneration - 2 or 3 units
- 8 - System #8 Single Timeclock, Meter, or Sensor Delayed Alternator Regeneration With Immediate Service Transfer (No Reserve Required)
- 9 - System #9 Individual Timeclock, Meter or Sensor Alternator Regeneration - 2 or 3 units
- 10 - System #10 (System #6/#4) 2 unit Single Timeclock, Meter, or Sensor Series Regeneration System With a Single Unit Timeclock Meter or Sensor System.
- 11 - System #11 (System #7/#4) 2 Unit Single Timeclock Meter, or Sensor Alternator Regeneration System With a Single Unit Timeclock, Meter or Sensor System.
- 12 - System #12 (System #8/#4) 2 Unit Single Timeclock, Meter, or Sensor Delayed Alternator Regeneration With Immediate Service Transfer and a Single Unit Timeclock, Meter or Sensor System.
- 13 - System #13 (System #9/#4) 2 Unit Individual Timeclock, Meter, or Sensor Alternator Regeneration System With a Single Unit Timeclock, Meter, or Sensor System.

#4 - Single Unit/9000-9500 Timeclock, Meter or Sensor Regeneration - This system is automatically selected when the system Size is one. When this number is active, the controller and a regeneration valve will operate together as part of a single unit regeneration control system. Only Unit #1 inputs on the controller will be continuously monitored. The controller will determine that regeneration is required for the unit based on the set Regeneration Type. The Timed Auxiliary Output #1 will automatically be set to be activated for the full time period that the controller is in Regeneration. The option setting display will appear as **[S-----F] [E-----S]**. This option setting can be reset as required. The Timed Auxiliary Output #2 option setting can be set as required.

#5 - Individual Timeclock, Meter, or Sensor Interlocked Regeneration - 2-3 Units - When this number is selected, the controller and two to three regeneration valves will operate together as part of a multi unit interlocked regeneration control system. Each unit in the system will have its own Regeneration Type Option Setting and its flow meter/sensor input active. Based on this setting, the controller will determine how and when a regeneration cycle will be initiated. The controller will delay the start of regeneration if another unit is already in regeneration. Once that unit has completed a regeneration cycle, and has returned to Service, the controller will then be able to proceed with the regeneration of the unit with the next longest regeneration request time. No more than one unit will be in regeneration at a time. The Timed

Systemax 2000

Option Setting Programming - Cont'd

Auxiliary Output #1 will automatically be set to be activated for the full time period that the controller is in Regeneration. The option setting display will appear as **[S-----F] [E-----S]**. This option setting can be reset as required. The Timed Auxiliary Output #2 option setting can be set as required.

#6 - Single Timeclock, Meter or Sensor Regeneration - 2-3 Units - When this number is selected, the controller and two to three regeneration valves will operate together as part of a multi unit series regeneration control system. Only Unit #1 will have its flow meter/sensor input active. There will be only a System Regeneration Type Option Setting. Based on this setting, the controller will determine how and when a regeneration cycle will be initiated. When the controller determines that regeneration is required for the system, it will initiate a regeneration cycle of Unit #1 first, followed by #2, then #3, if installed. Regeneration of Units #2 and #3 will begin after the preceding unit has finished Regeneration and returned to Service. The controller will delay the start of regeneration if another unit is already in regeneration. No more than one unit will be in regeneration at a time. The Timed Auxiliary Output #1 will automatically be set to be activated for the full time period that the controller is in Regeneration. The option setting display will appear as **[S-----F] [E-----S]**. This option setting can be reset as required. The Timed Auxiliary Output #2 option setting can be set as required.

#7 - Single Timeclock, Meter, or Sensor Alternator Regeneration - 2-3 Units - When this number is selected, the controller and two to three regeneration valves will operate together as part of a multi unit alternating regeneration control system. Only Unit #1 will have its flow meter/sensor input active. There will be only a System Regeneration Type Option Setting. Based on this setting, the controller will determine when and how a regeneration cycle will be initiated. During normal operation each unit will be in one of three states: Service, Regeneration or Standby. Only one unit will be in Regeneration the other one or two units will be in Service or Standby. Regeneration of a unit will only begin after all units have left Standby and have returned to Service. When the regeneration cycle is complete, the regenerated unit will enter the Standby State. In this state the controller will wait to bring that unit back into Service until a regeneration request has been made of the next downstream unit. The controller will first bring the unit in Standby back into Service, then take the downstream unit into Regeneration.

The Timed Auxiliary Output #1 will automatically be set to be activated for the full time period that the controller is in Regeneration and Standby. This option setting display will appear as **[E-----S]** and can be reset as required. The start setting will not be viewed and is automatically fixed at **[S-----F]**. The Timed Auxiliary Output #2 option setting can be set as desired. Unit rotation is to be Unit #1 to #2 to #3 then back to #1.

#8 - Single Timeclock, Meter, or Sensor Alternator Regeneration With Immediate Service Transfer - 2 or 3 Units - When this number is selected, the controller and two to three regeneration valves will operate together as part of a multi unit delayed alternator regeneration control system with immediate transfer of valve operation from Service to Standby once its unit's capacity is exhausted. When this unit's Regeneration Time is reached, a normal regeneration cycle is then initiated. System operation is identical to System Type #7 except there is not a Reserve Capacity. Only one unit will be able to regenerate at a time.

#9 - Individual Timeclock, Meter or Sensor Alternator Regeneration - 2 or 3 Units - When this number is selected, the controller and two to three regeneration valves will operate together as part of a multi unit individual timeclock, meter, or sensor alternator regeneration control system. System operation is identical to System Type #7 except there are separate Timeclock/Meter/Sensor inputs to the controller for each unit in the system. Only one unit will be able to regenerate at a time.

#10 - (System #6 / #4) 2 Unit Single Timeclock, Meter, or Sensor Series Regeneration System with a Single Unit Timeclock, Meter, or Sensor System - 3 Units Only - When this number is selected, the controller and three regeneration valves will operate as part of a multi unit regeneration system that contains two independent subsystems. System operation for Units #1 and #2 are the same as System Type #6. System operation for Unit #3 is identical to System Type #4. Only two units can be in regeneration at a time, Unit #3 and either Unit #1 or #2.

#11 - (System #7 / #4) 2 Unit Single Timeclock, Meter, or Sensor Alternator Regeneration System with a Single Unit Timeclock, Meter, or Sensor System - 3 Units Only - When this number is selected, the controller will operate as part of a multi unit regeneration system that contains two independent subsystems. System operation for Unit #1 and #2 are the same as System Type #7. System operation for Unit #3 is identical to System Type #4. Only 2 units can be in regeneration at a time, Unit #3 and either Unit #1 or #2.

Systemax 2000

Option Setting Programming - Cont'd

#12 - (System #8 / #4) 2 Unit Single Timeclock Meter, or Sensor Delayed Alternator Regeneration with Immediate Service Transfer and a Single Unit Timeclock, Meter or Sensor System - 3 units only -

When this number is selected, the controller will operate as part of a multi unit regeneration system that contains two independent subsystems. System operation for Units #1 and #2 are the same as System Type #8. System operation of Unit #3 is identical to System Type #4. Only two units can be in regeneration at a time, Unit #3 and either Unit #1 or #2.

#13 - (System #9/#4) 2 Unit Individual Timeclock, Meter or Sensor Alternator Regeneration System with a Single Unit Timeclock, Meter, or Sensor System - 3 Units Only -

When this number is selected, the controller will operate as part of a multi unit regeneration system that contains two independent subsystems. System operation for Units #1 and #2 are the same as System Type #9. System operation for Unit #3 is identical to System type #4. Only two units can be in regeneration at a time, Unit #3 and either Unit #1 or #2.

Number of Units in Service

Those option setting is only available with a System Size of 3 and System Types 7 or 9 set. It allows the user to select either one or two units in service (with the other 2 or 1 units in standby). Use the Up and/or Down arrows to set the display for **[1 ONLINE]** or **[2 ONLINE]**. No matter how many units are set to be in service, when a regeneration is called for, all units will first be brought to service and then the appropriate unit will be put back into standby.

Regeneration Type Option Setting Display

This option setting has a display with a range of 1 to 13. There are 13 different regeneration options that can be selected by the user in this mode. The options to be available, and their option display Codes, are shown below:

1 - Timeclock Delayed 2 - Meter Immediate 3 - Meter Delayed with Standard Reserve 4 - Meter Delayed with Daily Variable Reserve 5 - Meter Delayed with Calender Variable Reserve 6 - Sensor Immediate 7 - Sensor Delayed 8 - Sensor Immediate With Totalizer 9 - Sensor Delayed with Totalizer 10 - Manual Initiation 11 - Meter Delayed Without Reserve 12 - Sensor Delayed Without Reserve 13 - Sensor Delayed/Totalizer Without Reserve

Timeclock or Sensor Regeneration

With Timeclock or Sensor immediate or Delayed Regeneration selected, any volume or flow rate (flow meter) related option settings will not be capable of being viewed or set. With any Immediate Regeneration Type selected, the Regeneration Time Option Setting will not be viewed or able to be set.

Sensor Regeneration Only

With any Sensor Regeneration Type set, a second flashing display will be viewed. This four digit display setting will flash until the number displayed is changed. This display is used to set the time, in minutes, a sensor input signal must be received before a regeneration of the system or unit is initiated. A 000.0 setting will initiate a regeneration cycle immediately.

Manual Initiation

With Manual Initiation set, a second flashing display will be viewed. This single digit will flash until the number displayed is changed. This display is used to set the Regeneration Type Code # to be used in determining when to signal the user to initiate a regeneration of the system or unit.

Systemax 2000

Option Setting Programming - Cont'd

Regeneration Type Decision Making -

Option Code #	Description
1	Timeclock Delayed - The controller will determine that a regeneration is required when the set Delayed Regeneration Time is reached. Regeneration to begin immediately. When the Standard or Calendar Day Regeneration Override Option is set, regeneration can only begin automatically selected days at the desired time.
2	Meter Initiation - The controller will determine that regeneration is required when the available volume of treated water drops to zero. Regeneration to begin immediately.
3	Meter Delayed with Standard Reserve - The Controller will determine that a regeneration is required when the available volume of treated water drops to or below the reserve capacity. The reserve capacity is automatically calculated at 1/3 the total capacity of the unit/system. Regeneration to begin at the set Regeneration Time.
4	Meter Delayed with Daily Variable Reserve - The controller will determine that a regeneration is required when the available volume of treated water drops to or below the calculated reserve. This reserve is based on water usage patterns for the previous 48 hours. Regeneration is to begin immediately at the set Regeneration Time.
5	Meter Delayed with Weekly Variable Reserve - The controller will determine that a regeneration is required when the available volume of treated water drops to or below the calculated reserve. This reserve is based on water usage data stores from 6, 13 and 20 days prior. Regeneration is to begin immediately at the set Regeneration Time.
6	Sensor Immediate - The controller will monitor treated water usage by means of a resin bed sensor or some other device. Regeneration will begin immediately when a confirmed signal is received from the sensor.
7	Sensor Delayed - The controller will monitor treated water usage by means of a resin bed sensor or some other device. Regeneration will begin at a preset regeneration time after a confirmed signal from the sensor is received.
8	Sensor Immediate with Totalizer - The controller will monitor treated water usage by means of a resin bed sensor or some other device. Regeneration will begin immediately when a confirmed signal is received from the sensor. The Totalizer Display will be viewed and the Chemical Pump Output feature will be able to be programmed.
9	Sensor Delayed with Totalizer - The controller will monitor treated water usage by means of a resin bed sensor or some other device. Regeneration will begin at a preset regeneration time after a confirmed signal from the sensor is received. The Totalizer Display will be viewed and the Chemical Pump Output feature will be able to be programmed.
10	Manual Initiation - The controller will monitor treated water usage as per set Regeneration Type # and will flash the Manual Regeneration Button Indicator as well as the Program Select Button of the unit to be regenerated. With Single Timeclock, Meter, Sensor Systems (Systems #4, #6, #7, #8), the System Program Select Button will be flashing along with the Manual Regeneration Button instead of an individual unit Programme Select Button. Regeneration is to be delayed, regardless of the set Regeneration Type, until initiated in a normal manner by the user. (Pushing the Manual Regeneration Button then the indicated Program Select Button of the depleted unit.) If Timed Auxiliary Output #2 Option is not set the controller will also activate Timed Auxiliary Output #2 until the unit indicated is sent into regeneration.

Systemax 2000

Option Setting Programming - Cont'd

- 11 **Meter Delayed Without Reserve** - The controller will determine that a regeneration is required when the available volume of treated water drops to or below zero. System alternation will then proceed as in System #7, however regeneration of the depleted unit will be delayed until the set Regeneration Time, Regeneration then to begin immediately. This Regeneration Type will be able to be selected only with System Type #8. There will not be a reserve capacity calculated or displayed.
- 12 **Sensor Delayed Without Reserve** - The controller will monitor treated water usage by means of a resin sensor or some other device. The controller will determine that a regeneration is required when a confirmed regeneration signal is sent from the sensor. System alternation will then proceed as in System #7, however regeneration of the depleted unit will be delayed until the set Regeneration Time. Regeneration then to begin immediately. This Regeneration Type will be able to be selected only with System Type #8. There will not be a need to adjust the sensor in such a way to create a reserve capacity.
- 13 **Sensor Delayed/Totalizer Without Reserve** - The controller will monitor treated water usage by means of a resin sensor or some other device. The controller will determine that a regeneration is required when a confirmed regeneration signal is sent from the sensor. System alternation will then proceed as in System #7, however regeneration of the depleted unit will be delayed until the set Regeneration Time. Regeneration then to begin immediately. This Regeneration Type will be able to be selected only with System Type #8. There will not be a need to adjust the sensor in such a way to create a reserve capacity. The Totalizer Display will be viewed and the Chemical Pump Output feature will be able to be programmed.

Regeneration Time Option Setting Display

This option setting sets up to two separate regeneration launch windows. One or both may be used and can be made as narrow or as wide as desired. The setting displays are identical to the time of Day Display except that the period will not be flashing. The first display **(1-S)** sets the start of Window #1. The second **(1-E)** sets the end of Window #1. The third **(2-S)** sets the start of Window #2. The fourth **(2-E)** sets the end of Window #2. Both windows will not overlap, they also cannot cross midnight. The second window can be turned off by setting the #2 Start Window Display to OFF. The launch window set on initial installations will be from 2:00 A.M./14:00, to 2:30 A.M./14.30 only, depending on the US/metric setting. Regeneration will only occur automatically within one of these two windows. This option setting is skipped when the Regeneration Type selected is #2.#6 or #8.

Flow Meter Size Option Setting Display

This option setting has a one digit display that will have a range of 0 to 6. There are seven different size options to choose from, each with a number code. The standard electronic meter sizes available and their option display codes are shown below:

0 - 3/8"	2 - 1.0"	4 - 2.0"	6 - Non-standard flow meter
1 - 3/4"	3 - 1.5"	5 - 3.0"	

When #6 is selected, a four digit display with a range of 1 to 9,999 will appear at the far left of the VFD. These digits will flash until the number displayed is changed. This option setting display is used to enter the number of meter pulses generated per unit of volume (gallons/litres) by the non-standard meter. The display settings are set by using the Up or Down Set Buttons.

Capacity Option Setting Display

This option setting instructs the controller as to the maximum treatment capacity of the unit # or system being programmed, including any reserve. With Regeneration Type options #2, #3, #4, #5, #10 or #11 selected, this set value is used as a starting point in a volume countdown, which becomes the Volume Remaining. The amount subtracted from Volume Remaining is based on the water flow that is sensed by the flow meter(s). A call for regeneration occurs when the Volume remaining falls below the set or calculated reserve capacity, or if there is

Systemax 2000

Option Setting Programming - Cont'd

Capacity Option Setting Display - Cont'd

no reserve, when the Volume remaining reaches zero, which is displayed as [- - - - -]. The type of regeneration initiation will be based on the Regeneration Type Option Setting.

When Meter Delayed with Daily/Weekly Variable Reserve Option is set, this value is also used in calculating the reserve capacity of the unit being set. This option setting consists of one 8 digit display. Depending on the US/metric option setting, this display will be set in gallons or litres. The Volume Remaining Display will count down from this set capacity to zero. This option setting is ignored and skipped by the controller when the Regeneration Type Option Setting is not #2, #3, #4, #5, #10 or #11.

Regeneration Override Option Setting Display

This option setting has nine different displays. Depending on the regeneration override type selected, two or eight different display settings will be viewed. All displays in this option setting can be viewed one at a time by pushing the appropriate Programme Select Button once per display. The first display **[CAL - - YES]** is used to inform the controller whether the user would like to use the Calendar Override Feature. By pushing the Up or Down Arrow Buttons the three right side digits will alternate displaying yes or no. If set to yes, the following series of seven displays will then appear:

[- - - - YES]

The programmer will then select the days of the week that a regeneration should occur, regardless of water usage. The first display is the calendar setting for Sunday. By pushing the Up or Down Arrow Buttons, the two or three right most digits will alternate displaying yes or no. A yes setting will permit the control to initiate a regeneration cycle on that day, a no setting will skip this day. A setting display for each day of the week will then follow with the arrow moving one space to the right for each day setting.

If **[CAL - - YES]** is set to **[CAL - - NO]** the controller will use the Standard Override feature. This feature is used to select the amount of days (24 hour periods) that can pass before a regeneration should occur, regardless of water usage. This setting consists of a two digit display that has a setting range of 1 to 99 days.

A position between 1 and 99 will display OFF and be used to cancel this option setting. The Standard Override Type will not be able to be viewed or set if the Calendar Day Override Type is set above.

Timeclock Regeneration Type will require one of these two override types to be active in order to initiate a regeneration. With either Timeclock/Meter Delayed/Sensor Delayed Regeneration Types set, regeneration will occur only at the set Regeneration Time. With either Meter Immediate/Sensor immediate Regeneration Types regeneration will occur immediately when the programmed amount of time has passed since the last regeneration cycle.

Regeneration Cycle Steps #1 through #6 Option Setting Displays

This option setting consists of 6 separate displays. One display per regeneration cycle step. Each display has a setting range of 0 to 999.9 minutes with a resolution of 0.1 minute. Timing is to start after the drive motor has reached the next position, not at the start of the drive signal.

An off position exists below 000.0 and above 999.9. It will be shown as the word OFF. It is used to skip a cycle step totally and return the unit immediately to Service or Standby. When 000.0 is set for a step, the controller will advance the valve to that cycle step but spend zero time in that step and go immediately to the next step. This setting is used in conjunction with a special Valve Programme Cam to repeat certain regeneration cycle steps before returning to Service or Standby. At the end of the last set cycle step, the controller will advance the valve in regeneration back to Service or Standby.

Systemax 2000

Option Setting Programming - Cont'd

Timed Auxiliary Output #1 and #2 Option Setting Displays

Both timed auxiliary outputs programme identically. They can be used to turn on a chemical pump during service, or turn off/on pumps, lights and sensors during a regeneration cycle. This option setting has two different groups of displays, Chemical Pump and Standard Output Groups.

The first display is used to inform the controller whether the programmer would like to use either Chemical Pump Output Feature. A **[CPO - - OP1]** or **[CPO - - OP2]** display setting will inform the controller which of these two Chemical Pump Output is to be used and advance the programmer to the proper first and second Chemical Pump Group displays. The Chemical Pump Output types available are:

OP1 – Volume On / Time Off

OP2 – Volume On / Volume Off

When Chemical Pump Output Option #1 (OP1) is selected, the control will activate the Timed Auxiliary Output #1 or #2 immediately, for a set period of time, when the preset volume has been reached during Service. With individual flow meter systems there can be an output from each unit. With single flow meter systems there can be only one output which will operate from Unit #1.

By pushing the Up or Down Arrow Buttons the three right side digits will alternate displaying OFF, OP1 or OP2. If this display is set to OP1 the next 2 displays will appear as:

[UOLXX,XXX] THEN [runX,XXX.X]

This first display **[UOLXX,XXX]** is used to set the number of volume units that will be allowed to flow through the softener before the Timed Auxiliary Output #1 or #2 is activated. This setting has a range of 1 to 99,999 volume units. The second setting **[runX,XXX.X]** contained the Timed Auxiliary Output #1 or #2 Activation Run Time setting. This setting has a range of 0 to 9,999.9 minutes. Both option settings are adjusted by using the Up or Down Set Buttons. The volume count is reset at the activation of the output. This option setting is not able to be viewed or set when the Regeneration Type is #1, #6, #7 or #12.

When Chemical Pump Output Option #2 (OP2) is selected, the control will activate the Timed Auxiliary output #1 or #2 immediately, for the set amount of flow volume, when the programmed trigger volume has been reached during Service. With individual flow meter systems there can be an output from each unit. With single flow meter systems there can be only one output which will operate from Unit #1.

By pushing the Up or Down Arrow Buttons the three right side digits will alternate displaying OFF, OP1 or OP2. If this display is set to OP2, the next 2 displays will appear as:

[On-XX,XXX] THEN [OFFXX,XXX]

This first display **[On-XX,XXX]** is used to set the number of volume units that will be allowed to flow through the softener before the Timed Auxiliary Output #1 or #2 is activated (Output Activation Volume). This setting has a range of 1 to 99,999 volume units. The second setting **[OFFXX,XXX]** contains the Timed Auxiliary Output #1 or #2 Run Volume setting. This setting has a range of 0 to 99,999 volume units. Both option settings are adjusted by using the Up or Down Set Buttons. The volume count is reset at the activation/deactivation of the output. This option setting is not able to be viewed or set when the Regeneration Type is #1, #6, #7 or #12.

When Standard Output Option (CPO - - OFF) is selected, the Timed Auxiliary Output #1 or #2 will function as a Standard Output with one on/off time during Regeneration. The first and second Standard Output Group displays will then be able to be viewed and set.

Systemax 2000

Option Setting Programming - Cont'd

This option consists of 2 displays **[S - - X,XXX.X] [E - - X,XXX.X]** The first five digit setting **[S - - X,XXX.X]** contains the Timed Auxiliary Output #1 or #2 Activation Start Time setting. This turn on time is referenced from the moment timing begins for Regeneration Cycle Step #1 as sensed by the Home and Step Switch inputs. This setting has a range of 0 to 9,999.9 minutes. The second five digit setting **[E - - X,XXX.X]** contains the Timed Auxiliary Output #1 or #2 Activation End Time setting. This end time is also referenced from the moment timing begins for Regeneration Cycle Step #1. This setting has a range of 0 to 9,999.9 minutes.

The controller will not allow an end time setting equal or less than the start time setting. A special setting **[S ---- OFF]** below **[S -- 0,000.0]** and above **[S -- 9,999.9]** will cancel this option. There will be a special setting **[E ----- S]** below **[E -- 0,000.0]** and above **[E -- 9,999.9]** that is used in programming the output to turn off when the unit is returned to Service. In order for this to happen, the display setting would be set to **[S—X,XXX.X] [E ----- S]**.

With Valve Types #1, #2, #4 or #5 set, there will be another setting below **[S -- 0.000.0]** and above **[S -- 9,999.9]**. It will be shown as **[S ----- F]**. It is used to activate this output immediately upon the unit entering regeneration, before Regeneration Step #1 begins. This feature will prevent any untreated water bleed-through while the units are transitioning in and out of service. Timed Auxiliary Output #1 settings will not be able to be viewed or set if Valve Type #3, #6 and System Types #7, #8, #9, #11 or #13 are also set. Timed Auxiliary Output #2 settings will not be able to be viewed or set if Regeneration Type #10 is also selected.

Regeneration Lockout Option Setting Display

When this option is selected the controller will not allow a system/unit to go into regeneration until the signal to that systems/units Regeneration Lockout has been removed. This option has five settings:

OFF	On1	On3
	On2	On4

OFF cancels this option

On1 will not allow the control to initiate a regeneration of that unit (Individual lockout)

On2 is similar to On1, but will also activate Timed Auxiliary Output #2 until any button on the control is pushed.

On3 is similar to On1 except only the Regeneration Lockout Input for Unit #1 is active, but will lock out the whole system.

On4 is similar to On3, but will also activate Unit #1's Timed Auxiliary Output #2 until any button on the control is pushed.

Whenever this feature is active, a second flashing display will be viewed. This four digit display setting will flash until the number displayed is changed. This display is used to set the time, in minutes, a regeneration lockout signal must be received before a regeneration of the system or unit is initiated. A 000.0 setting will lockout a regeneration cycle immediately.

The settings On3 and On4 are used when one lockout signal is provided to prevent regeneration of any unit in the system. If an on time is set for Timed Auxiliary Output #2 then setting On2 or On4 will not be viewed. A regeneration lockout signal must be removed for at least one minute before the lockout is actually cleared.

Programme Lockout Option Setting Display (PL)

When this option is selected, the controller will not allow the user to go into the Programme Mode until the desired System/Unit #s Programme Select Button is pushed and held for a specified time. This option setting consists of one display. Setting the display to OFF will cancel this feature.

Setting the display to a specific number will activate this feature. This display has a range of 1 to 99 seconds and is used to set the minimum amount of time (in seconds any Programme Select Button must be pushed and held before the Programming Mode is entered. Regardless if this feature is active or not, exiting the Programming Mode will remain unchanged.

Systemax 2000

Option Setting Programming - Cont'd

Unit Power On / Reset Mode

This setting determines the behaviour of the controller after a reset or restoration of power. Use the Up/Down Arrow buttons to select between **[AUTOrGEN]** and **[NO AUTO]**. With **[AUTOrGEN]** selected, the controller will go through its normal power up sequence and then initiate, after a four minute delay, a System #6 style series regeneration of each unit in the system. The Time of Day display will be flashing until any button is pressed on the keypad. This is the indication that there was a total loss of power or a controller reset. Use this setting if a fully initialised system is required after power restoration.

With **[NO AUTO]** selected, the controller will go through its normal power up sequence and then restore the system to the conditions as last saved in non-volatile memory. If a unit was in regeneration, then only that unit will be set to repeat the entire regeneration cycle. Otherwise all units will be set to their last known service / standby status. The Time of Day Display will not be flashing. Actual times displayed and volumes remaining may not match actual system status. Use this setting if a controller has frequent reset problems or there are frequent power outages and a battery backup is not installed.

This option will be set to **[AUTOrGEN]** automatically and will not be able to be viewed or changed if the number of Units in Service option Setting is set to **[1 ONLINE]**.

Systemax 2000

Specifications

ELECTRICAL SPECIFICATIONS-

Electrical Safety

The power supply to the controller must be unswitched and be fuse or circuit breaker protected at 15 A. All system wiring must be done in accordance to local electrical codes.

Recommended Operating Voltage

Input Voltage Tolerance: -20% and +10% of 120v, and 240V 50/60Hz
-10% and +20% of 24V 50/60Hz

Recommended Maximum Operating Currents

1. Total System: 15A (Controller and all equipment powered through the controller)
2. Individual Units: 6.3A (Total of all units and controller not to exceed 15A)
3. Individual Relay Outputs: 6.3A at 250VAC (Total of all units and controller not to exceed 15A)
4. Total of all +5VDC Sensor Power Supply Outputs not to exceed 0.3A
5. Operating Current of Controller Electronic Circuitry: 0.5A (includes 0.3A Max. +5VDC Sensor P.S. Current)

Battery Backup

1. Battery Backup: Six "AA" size Alkaline Batteries
2. Minimum Battery Backup Time: Approximately 24 hours (Using six Alkaline Batteries at Full Capacity)
3. Depending on Flow Meter/Sensor/Regeneration Lockout Input usage, battery type and remaining battery capacity, minimum battery backup time may vary.
4. Always instal backup batteries with the control connected to line power.

Input Wiring

1. For best performance route all low voltage cables and devices (flow meters, hardness sensors, etc.) away as much as possible from any sources of electrical interference (motors, switches, etc.)
2. With Single Meter/Sensor System Types always connect the system meter/sensor to Unit #1
3. With Single System Regeneration Lockout and Chemical Output Types always connect the system lock-out device/chemical pump to Unit #1

ENVIRONMENTAL SPECIFICATIONS –

Controller Environmental Specifications

Enclosure IP 64
Controller Ambient Operational Temperature Rating 0-70 degrees C
Humidity Range of 0 to 95% non-condensing
Controller Storage Temperature Rating -40 to +80 degrees C
Storage Humidity Range of 0 to 95% non-condensing

Installation in Damp locations

Only the controller itself is installed in an IP64 enclosure, any equipment connected to it may not meet the same standard. Excessive moisture on all electrically powered equipment not designed for this environment may lead to erratic performance and premature failure of that piece of equipment and/or the controller. Please follow safe operating practices when installing and operating this equipment

On initial installations during cold weather it is recommended that the installer warm the controller up to room temperature before operating.

Systemax 2000

Controller Input / Output Electrical Requirements

Home and Step Switch Inputs

Two inputs per unit. The controller monitors continuously two low voltage dc switch closure inputs for signals sent from each unit in the system. These signals are used by the controller to determine the present status of each system unit as well as to control valve drive motors properly through their Valve Drive Outputs. The Home Signal is only present when the unit is in service. The Step Signal changes state during a regeneration cycle. A Valve/ Stager Homing and Programme Cam are typically used to generate these signals. Any time the Home Signal is lost for over one minute, with a valve in Service, the controller will indicate this problem by displaying an Upper Drive Error Message [**Ud Error**] on the VFD. Also the Programme Selector Button LED for the unit with the problem will flash rapidly. Any calls for regeneration or of bringing units back into service will be delayed until the error is cleared. This is done automatically by removing the error condition.

Lower Drive Input

One input per unit. The controller monitors continuously a low voltage dc switch closure input for signals sent from each unit in the system (Valve Type #3 and #6 only). A signal present (switch closed) at this input will indicate that the Lower Drive Valve is in a regeneration or standby position. The controller will indicate that it is waiting for this signal to be removed by flashing either the Regeneration or Standby Status LED for that specific unit.

A signal absent (switch open) at this input will indicate that the Lower Drive Valve is in a service position. The controller will indicate that it is waiting for this signal to be sent by flashing the Service Status LED for that specific unit. If the Lower Drive Input Signal is not removed within 60 seconds, (returning a unit to service) or not received within 60 seconds, (sending a unit to regeneration or standby) a Lower Drive Input Error Message [**Ld error**] will be viewed on the VFD. Also the Programme Selector Button LED for the unit with the problem will flash rapidly. Any calls for regeneration or of bringing units back into service will be delayed until the error is cleared. This is done automatically by removing the error condition.

Flow Meter Inputs

One input per unit. This input requires a Hall Sensor type solid state signal generator. This sensor is “wetted” with +5vdc from the controller. Signals sent to these inputs will inform the controller to increment or decrement all active volume related displays, which are determined by the Regeneration Type selected. As an indication of the current status of the Flow Meter Input, the controller will flash the Flow Meter Input LED once per flow meter pulse received by the controller.

Sensor Inputs

One input per unit. This input requires a dry contact switch closure. This switch is wetted with +5vdc from the controller. A signal sent to one of these inputs will inform the controller to initiate a regeneration cycle based on which Sensor Regeneration Type is selected. If after two regenerations, this signal has not been removed, the control will not initiate any further regeneration cycles. As an indication of the Sensor Input failure, the controller will flash the Sensor Input, Manual Regeneration, and the Unit #s Programme Select Button LEDs together. In order to clear this failure mode, a manual regeneration is required for the unit with the Sensor Input problem. The control will then resume normal operation.

Regeneration Lockout Input

One input per unit. This input requires a dry contact switch closure. This switch is wetted with +5vdc from the controller. A signal sent to one of these inputs will inform the controller to prevent the regeneration of that system/ unit number. The regeneration Lockout Input LED will flash from the moment Regeneration Lockout Input Signal has been received until the set minimum signal on time has been reached, and then remain on until the signal is removed.

Timed Auxiliary Output #1

One SPDT output per unit. The controller has the capability to drive either an AC or DC powered device for a specified period of time as set in the option setting Timed Auxiliary Output #1. The relay output is rated at 6 amps at 30 Vdc or 240Vac. The Timed Auxiliary Output #1 LED of the unit selected by its Display Selector Button will turn on when this output is active.

Systemax 2000

Controller Input / Output Electrical Requirements - Cont'd

Timed Auxiliary Output #2

One SPDT output per unit. The controller has the capability to drive either an AC or DC powered device for a specified period of time as set in the option setting Timed Auxiliary Output #2. The relay output is rated at 6 amps at 30 Vdc or 240Vac. The Timed Auxiliary Output #2 LED of the unit selected by its Display Selector Button will turn on when this output is active.

Valve Drive Outputs

One SPDT output per unit. The controller has the capability to drive either an AC or DC powered device for a specified period of time as set in regeneration cycle programming. The relay output is rated at 6 amps at 30 Vdc or 240Vac. The Valve Drive output LED of the unit selected by its Display Selector Button will turn on when this output is active.

Systemax 2000

Controller Programme

Installation Site:

Installation Date:

OEM / Installer:

Revision Number of Programme:

	System	Unit #1	Unit #2	Unit #3
US /metric	_____			
System Unit Size	_____			
Valve Type	_____	_____	_____	_____
System Type	_____			
(Number of Units ON line)	_____			
Regeneration Type	_____	_____	_____	_____
(#10 Regeneration Type)	_____	_____	_____	_____
(Minimum Signal On Time)	_____	_____	_____	_____
Regeneration Time				
(Window #1 S/E)	_____	_____	_____	_____
(Window #2 S/E)	_____	_____	_____	_____
Flow Meter Size	_____	_____	_____	_____
(#6 Pulses per US gallon/Litre)	_____	_____	_____	_____
Capacity US gallons / Litres	_____	_____	_____	_____
Regeneration Override				
Calendar Day Override (Circle Override Days)	Su Mo Tu We Th Fr Sa	Su Mo Tu We Th Fr Sa	Su Mo Tu We Th Fr Sa	Su Mo Tu We Th Fr Sa
Standard Override (Max. Days in Service)	_____	_____	_____	_____


Systemax 2000

	System	Unit #1	Unit #2	Unit #3
Regeneration Cycle (1 - 6)				
Step #1 (Typically Backwash)	_____	_____	_____	_____
Step #2 (Typically Brine Draw/ Slow Rinse)	_____	_____	_____	_____
Step #3 (Typically Rapid Rinse)	_____	_____	_____	_____
Step #4 (Typically Brine Tank Refill)	_____	_____	_____	_____
Step #5 (Typically Cancelled)	_____	_____	_____	_____
Step #6 (Typically Cancelled)	_____	_____	_____	_____
Timed Auxiliary Output #1				
Chemical Pump Output				
Volume Act. Count - US gall / Litres	_____	_____	_____	_____
Output Run Time / Volume	_____	_____	_____	_____
Standard Output				
Start Time	_____	_____	_____	_____
End Time	_____	_____	_____	_____
Timed Auxiliary Output #2				
Chemical Pump Output				
Volume Act. Count - US gall / Litres	_____	_____	_____	_____
Output Run Time / Volume	_____	_____	_____	_____
Standard Output				
Start Time	_____	_____	_____	_____
End Time	_____	_____	_____	_____
Regeneration Lockout				
Minimum Signal On Time	_____	_____	_____	_____
Programme Lockout				

Reset Mode (Circle One)	Auto Regeneration ON / OFF			

Systemax 2000

Enclosure Assembly




Systemax 2000

Enclosure Assembly - Parts List


Item No.	Quantity	Part No.	Description
1	1	18576	Power board support bracket
2	4	18292	Spacer
3	1	17877-01	Power circuit board (24v/XX relays)
4	8	10342	Nut - #16-32
5	1	18283	Ribbon harness - 60 pin
6	1	18760	Instruction label
7	1	19675	Fuse holder
8	1	18575	Display board support bracket
9	4	19293	Nylon spacer
10	1	18715-10	Display circuit board
11	1	18311	Switch pad
12	2	12436	Hinge
13	1 - 9	18339	Plug-in relay 12VDC
14	2	17831	Battery holder
15	1	18854	Circuit board shield
16	1	18607	Enclosure assembly
17	2	19367	Cover screw
18	1	13547	Strain relief
19	1	26259	Transformer 105Va
20	1 - 3	19011-01	Interlock cable assy - 2.1m
or	1 - 3	19011-02	Interlock cable assy - 4.2m
or	1 - 3	19011-03	Interlock cable assy - 6.3m

Systemax 2000

Standard 2750 / 2850 / 3150 Single Piston Valves - Wiring scheme




TB1—High voltage terminal block
TB2—Low voltage terminal block
IC1—Interlock cable receptacle
F1—Timed auxiliary output #1 fuse
F2—Timed auxiliary output #2 fuse
VDM—Valve drive motor
HCAM—Valve homing cam
SCAM—Valve step cam
SW1—Valve homing switch
SW2—Valve step switch
VDO—Valve drive output
TAO1—Timed auxiliary output #1
TAO2—Timed auxiliary output #2



S1—Solenoid ON during regeneration
M1—Device OFF during regeneration
M2—CPO device ON / OFF during service


TYPICAL OUTPUT WIRING



TYPICAL INPUT WIRING

Systemax 2000

Standard 2900 / 3900 Double Piston Valves - Wiring scheme



Systemax 2000

Controller Troubleshooting

1. No Displays

- Check power supply connections and external switches
- Check controller & valve power heads for water spray. If found, dry all electrical components before operation.

2. Dim Displays

- Check voltage of power supply. It should be 230vac +/- 10%
- Check controller & valve power heads for water spray. If found, dry all electrical components before operation.

3. Control locked up, displays function but never change.

- Check controller & valve power heads for water spray. If found, dry all electrical components before operation.
- Push reset button located on the rear lower right-hand corner of the display circuit board. The controller will go immediately to Start Mode. No reprogramming will need to be done.
- Or, disconnect the controller. Disconnect the backup battery pack, wait 10 seconds. Reconnect the controller, reset the time of day etc. & reconnect the battery backup. The controller will go immediately to Start Mode. No reprogramming will need to be done.
- As a last resort, push & hold the System and Unit #3 Display Selector Buttons for 25 seconds. This will return the controller to the Start Mode and reset all programming functions to the factory default settings.

4. Control functions normally but the valve sequencing appears to be wrong.

- Check interlock cable routing - Unit #1 cable must go to Valve #1, #2 to #2 & #3 to #3
- Check that the Valve Type setting is correct.

5. Volume Remaining Display is below reserve or at zero but valve does not regenerate.

- Check status displays of each unit for the following:
 - a). A Regeneration Lockout signal
 - b). Upper or Lower Drive Input Signal Failure.
[Ld Error] or [Ud Error] on VDF & a rapidly flashing Unit #1 Program Select Button.
 - c). Another unit is in regeneration.
 - d). Valve Drive Output LED is ON
- If a). was the problem, remove the lockout signal.
- If b). was the problem, check valve wiring and microswitch plug connections. Then manually regenerate valve with Upper / Lower Drive Input failure (the unit # with the rapidly flashing Program Select Button).
- If c). was the problem, wait until unit in regeneration returns to Standby or Service or step it through the remainder of its regeneration.
- If d). was the problem, check Valve Drive Relay for that unit on the power circuit board. Unplug & replace if failed. If relay OK, check valve drive motor and replace if failed.

6. Adjacent VFD display segments or digits are on dimly when they should be off.

- Dry out moisture on Display Circuit board.

Systemax 2000

Notes:
