

Selanex

working for the OEM

Fleck SE Timers vs. Electronic Meters

Programming Factors

Valve	Meter size	Factor
2510SE-Turbine	3/4in	F - 5.3
2510SE-Axial	3/4in	F 35.1
2750SE-Turbine	1in	F - 2.1
2850SE-Turbine	1-1/2in	F - 1.0
4600SE-Turbine	3/4in	F - 5.3
4600SE-Axial	3/4in	F 35.1
5600SE-Turbine	3/4in	F - 5.3
5600SE-Axial	3/4in	F 35.1
5000SE-Turbine	3/4in	F - 5.3
5000SE-Axial	3/4in	F 34.6
9000SE-Turbine	3/4in	F - 5.3
9000SE-Axial	3/4in	F 35.1
9100SE-Turbine	3/4in	F - 5.3
9500SE-Turbine	1-1/2in	F - 1.0
2900SE-Turbine	2in	F - 0.5

